Environment Protection Licence Licensee - Origin Energy Uranquinty Power PTY LTD

Environment Protection Licence Number - 12490

Pollution Monitoring - Nitrogen Oxides

Sample Period - December 2016 - November 2017

Sample Location	Data Sort	Dec-16	Jan-17	Feb-17	Mar-17	Apr-17	May-17	Jun-17	Jul-17	Aug-17	Sep-17	Oct-17	Nov-17	Year To date	Units of Measure	Licence Limit Conditions	
																mg/m3	Percentile
Sample Point:	Average	22	21	25	22	27	25	24	25	24	26	27	26	25	mg/m3	-	-
EPA Identification No. 1	Minimum	7	7	20	8	22	21	21	21	12	9	23	8	7	mg/m3	-	-
Turbine Stack 1	Maximum	48	51	46	50	51	51	44	38	40	49	47	51	51	mg/m3	51	100
Sample Point:	Average	27	23	22	28	29	30	30	31	30	32	33	30	29	mg/m3	-	-
EPA Identification No. 2	Minimum	9	7	15	7	24	27	27	26	27	9	29	9	7	mg/m3	-	-
Turbine Stack 2	Maximum	48	51	46	46	51	45	47	48	51	51	51	49	51	mg/m3	51	100
Sample Point:	Average	23	23	18	24	29	30	27	27	26	28	30	31	26	mg/m3	-	-
EPA Identification No. 3	Minimum	8	8	11	8	8	26	23	24	22	24	25	26	8	mg/m3	-	-
Turbine Stack 3	Maximum	43	51	37	46	50	50	46	40	39	43	43	46	51	mg/m3	51	100
Sample Point:	Average	22	20	32	25	26	27	25	25	24	27	26	25	25	mg/m3	-	-
EPA Identification No. 4	Minimum	8	8	15	8	22	23	22	22	14	10	21	9	8	mg/m3	-	-
Turbine Stack 4	Maximum	50	44	42	42	46	51	44	36	39	48	44	47	51	mg/m3	51	100
Date Data Sampled		Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous		**Note:**		
Date Data Downloaded		02/01/2017	01/02/2017	17/03/2017	11/04/2017	04/05/2017	08/06/2017	12/07/2017	02/08/2017	02/09/2017	03/10/2017	09/11/2017	11/12/2017		*"-" indicates no Unit run for reporting period*		
Date Data Published																	