

Environment Protection Licence Licensee - Origin Energy Uranquinty Power PTY LTD
 Environment Protection Licence Number - 12490
 Pollution Monitoring - Nitrogen Oxides
 REPORTING PERIOD 1 Dec 17 - 30 Nov 18



Sample Location	Data Sort	Dec-17	Jan-18	Feb-18	Mar-18	Apr-18	May-18	Jun-18	Jul-18	Aug-18	Sep-18	Oct-18	Nov-18	Year To date	Units of Measure	Licence Limit Conditions	
																mg/m3	Percentile
Sample Point:	Average	27	29	30	0	35	35	28	28	28	25	0	0	27	mg/m3	-	-
EPA Identification No. 1	Minimum	10	11	13	0	11	20	9	9	23	23	0	0	0	mg/m3	-	-
Unit 11	Maximum	50	48	49	0	50	51	49	50	50	44	0	0	51	mg/m3	51	100
Sample Point:	Average	28	30	32	32	29	32	28	32	31	31	0	0	31	mg/m3	-	-
EPA Identification No. 2	Minimum	9	10	17	27	10	25	25	29	29	12	0	0	9	mg/m3	-	-
Unit 12	Maximum	50	51	51	51	51	51	49	46	50	51	0	0	51	mg/m3	51	100
Sample Point:	Average	24	26	26	0	27	29	29	30	30	29	0	0	25	mg/m3	-	-
EPA Identification No. 3	Minimum	1	9	10	0	8	15	19	26	25	12	0	0	0	mg/m3	-	-
Unit 13	Maximum	50	42	42	0	45	50	51	43	51	51	0	0	51	mg/m3	51	100
Sample Point:	Average	23	24	21	24	23	25	27	28	27	26	0	0	25	mg/m3	-	-
EPA Identification No. 4	Minimum	8	8	8	6	8	10	11	25	23	22	0	0	6	mg/m3	-	-
Unit 14	Maximum	50	50	50	46	46	49	44	43	46	46	0	0	50	mg/m3	51	100
Date Data Sampled		Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Note: "-" indicates no Unit run for reporting period		
Date Data Downloaded		09/01/2018	14/02/2018	21/03/2018	16/04/2018	11/05/2018	13/06/2018	24/07/2018	09/08/2018	10/09/2018	03/10/2018	00/01/1900	00/01/1900				
Date Data Published		00/01/1900	00/01/1900	00/01/1900	00/01/1900	00/01/1900	00/01/1900	00/01/1900	00/01/1900	00/01/1900	00/01/1900	00/01/1900	00/01/1900				